



## **PUBLIC WORKS**

**DIRECTOR/CITY ENGINEER**  
City Office Building  
Box 755 320-235-4202  
**STREET/PARK SUPERINTENDENT**  
801 W. Hwy. 40 320-235-3827  
**WASTEWATER TREATMENT**  
3000 75th St. SW 320-235-4760  
Willmar, Minnesota 56201  
Fax 320-235-4917  
[www.ci.willmar.mn.us](http://www.ci.willmar.mn.us)

# **ADDENDUM NO. 1**

## **City of Willmar**

### **Engineering Services for the Lakeland Drive Interceptor/MinnWest Lift Station Project**

**TO: Prospective Proposers**

The following items related to the Engineering Services for Lakeland Drive Request for Proposal are being provided to you as additional information:

- Lakeland Drive reconstruction will be partially funded by State Aid.
- A drainage analysis will be needed for storm sewer needs along the corridor.
- A Quiet Zone for the railroad crossing at Lakeland Drive is desired, there has been no coordination to date with BNSF or MnDOT regarding implementing a Quiet Zone.
- The proposer should assume curbing all of Lakeland Drive as part of the reconstruction.
- A multi-use path is proposed along Lakeland Drive, but has not been identified as to location.
- Any watermain questions can be answered by Willmar Municipal Utilities.
- There is no signal work expected as part of the project.
- The street work is a complete reconstruction to be replaced with a standard City Section.
- Estimated project cost is \$6.5 M - \$7 M.

If you have any questions, feel free to call the City Engineer's Office at (320) 235-4202. Please acknowledge receipt of this addendum on your proposal. Thank you.

Sincerely,

**CITY OF WILLMAR**

Holly Wilson, PE  
Public Works Director

Js

